March 2006

# **64 Series Pressure Reducing Regulators**



Figure 1. 64 Series Regulator

# Introduction

## **Scope of Manual**

This manual provides instructions for the installation, adjustment, maintenance, and parts ordering for 64 Series regulators. These regulators usually are shipped separately for line or panel mounting or installed on other equipment. Instructions and parts lists for other equipment are found in separate manuals.

## **Product Description**

The 64 Series regulators are spring-loaded, directoperated devices typically used to deliver constant reduced pressure of gaseous fluids to pilot-operated controllers and other pneumatic instrumentation.

**Type 64:** Basic regulator for 3 to 15 psig (0,21 to 1,03 bar) outlet pressures

**Type 64R:** Internal relief version of the Type 64 **Type 64B:**  $NH_3$ - service version of the Type 64



64 Series



## **Specifications**

Connections	Pressure Registration		
End: 1/2-inch NPT	Internal		
Body Side: 1/4-inch NPT	Material Temperature Capabilities <sup>(1)</sup>		
Maximum Allowable Pressures <sup>(1)</sup>	-20° to 150°F (-29° <b>to 66°C)</b>		
Inlet: 250 psig (17,2 bar)	Spring Case Vent		
Operating Outlet: 150 psig (10,3 bar)	1/4-inch NPT with screen		
Outlet Pressure Ranges <sup>(1)</sup>	Weight		
See Table 1	2.25 pounds (1,01 kg)		
Port Diameter	<ul> <li>Options</li> <li>Closing cap for adjusting cap screw</li> <li>Triple scale outlet pressure gauge</li></ul>		
1/4-inch (6,35 mm)	(brass or stainless steel) <li>PTFE diaphragm protector</li>		

1. The pressure/temperature limits in this instruction manual or any applicable standard limitation should not be exceeded.

The Type 64R has an integral low-capacity relief valve. The valve stem seats against a drilled hole in the diaphragm plate. If the reduced pressure should exceed the set pressure, the diaphragm lifts off the valve stem so that a limited amount of excess pressure can flow into the spring case and bleed out through a screened vent.

A 64 Series regulator is also available with a handwheel. An optional handwheel is available for panel mounting.

## Installation

# 

Overpressuring a regulator or associated equipment may cause leakage, part damage, or personal injury due to bursting of pressure containing parts or explosion of accumulated gas. To avoid overpressure, provide an appropriate overpressure protection device (i.e., a relief valve) to ensure that the ratings listed in Specifications section will not be exceeded. A regulator should be inspected immediately for damage after any overpressure condition.

OUTLET PRESSURE	RANGE <sup>(1)</sup> , PSIG (bar)	SPRING PART NUMBER	SPRING COLOR
3 to 15	(0,21 to 1,03)	1D892327022	Red
3 to 20	(0,21 to 1,38)	1D751527022	Silver
5 to 35	(0,34 to 2,41)	1D665927022	Blue
30 to 60	(2,07 to 4,14)	1D745527142	Green
35 to 100	(2,41 to 6,90)	1E543627142	Yellow
80 to 150 <sup>(2)</sup>	(5,52 to 10,3) <sup>(2)</sup>	1P901327142	Brown

Table 1. Outlet Pressure Ranges and Spring Selection

1. Use qualified personnel when installing, operating, and maintaining these regulators. Before installation inspect for damage. Make sure there is not any foreign material in the regulator and all tubing and piping are clean and unobstructed.

2. If installing the regulator at an outside location, point the spring case vent in the downward direction to protect it from getting plugged or from collecting moisture, corrosive chemicals, or other foreign materials. Spring case vent orientation may be changed by rotating the spring case with respect to the regulator body.

3. Install the regulator so that flow is from the IN to OUT connection as marked on the regulator body.

## WARNING

If using this regulator on hazardous gas or flammable fluid, make sure that the vented gas is piped to a safe, well-ventilated area. Do not install a regulator so that the gas will be vented into a closed space. This could result in a fire or explosion which could cause personal injury or equipment damage.

4. To remotely vent the spring case, remove the screen, if present, and connect 1/4-inch NPT piping or tubing to the spring case connection. The piping or

tubing should vent the spring case to a safe location, have as few bends as possible, and have a screened vent on its exhaust end that is weather resistant and always pointed in the downward direction.

5. Like most regulators, 64 Series regulators have outlet pressure ratings lower than inlet pressure ratings. Although types with internal relief include limited downstream overpressure protection, all types may require additional relief protection for some service conditions if the actual inlet pressure can exceed the regulator outlet pressure rating or the pressure ratings of any downstream equipment. Inspect a regulator periodically and after any overpressure condition.

6. Each regulator is factory-set for the pressure setting specified on the order. If no setting is specified, outlet pressure is factory-set at the midrange of the control spring.

## Startup

Key numbers are referenced in Figure 2.

1. Slowly open the upstream and downstream shutoff valves while monitoring the outlet pressure with a gauge installed at some point downstream from the regulator. Pressure may also be monitored by installing a pressure gauge in the unused outlet connection.

2. If it is necessary to adjust the regulator:

• Loosen the locknut (key 13).

• Turn the adjusting screw (key 12) while monitoring the pressure. Turn clockwise to increase the set pressure; turn counterclockwise to decrease the set pressure.

• Tighten the locknut after adjustment is made.

## Shutdown

- 1. Close the upstream shutoff valve.
- 2. Close the downstream shutoff valve.

3. If vent valves are installed, open the vent valve between the regulator and the downstream shutoff valve. Then, open the vent valve between the regulator and the upstream shutoff valve.

4. If vent valves are not installed, safely bleed off both inlet and outlet pressures, and check that the regulator contains no pressure.

## Maintenance

Regulator parts are subject to normal wear and must be inspected and replaced as necessary. The frequency of inspection and replacement of parts depends upon the severity of service conditions as well as the requirements of local, state, and federal regulations.

# 

To avoid personal injury or equipment damage from sudden release of pressure or explosion of accumulated gas, do not attempt any maintenance or disassembly without first isolating the regulator from system pressure and relieving all internal pressure from the regulator.

## Disassembly

### Note

The body assembly (key 1) may remain mounted in a line or panel or on other equipment during disassembly as long as the entire regulator does not have to be replaced.

The following procedure describes how to completely disassemble the regulator. When part replacement or inspection is required, complete only those steps necessary to accomplish the task, and then start the assembly at the appropriate step. Key numbers are referenced in Figure 2.

1. Remove closing cap (not shown), if used.

2. Loosen locknut (key 13), and turn adjusting screw (key 12) counterclockwise so that spring tension is relieved.

3. Remove the cap screws and nuts (keys 14 and 15) that hold the spring case (key 2) on the body (key 1). Then, remove the spring case, regulator spring (key 4), and upper spring seat (key 11).

4. Remove the diaphragm assembly (key 9).

5. Unscrew and remove the stem guide (key 8) from the valve body.

6. Remove the stem seal O-ring (key 5) from the body. If the O-ring is to be replaced, it should be lubricated.

7. Unscrew the body plug (key 10). This permits removal of the valve spring (key 3) and the disk holder assembly (key 6).

## **Spring Installation**

Reassemble in the reverse of the above procedures.

1. Lubricate the upper spring seat and the exposed threads of the adjusting screw with Anti-Seize lubricant.

2. Position the spring case (key 2) over the spring and onto the regulator body (key 1). Orient the spring case vent as necessary.

3. Insert the cap screws and nuts (keys 14 and 15), and tighten them only finger tight.

4. Thread the adjusting screw and locknut (keys 12 and 13) into the spring case just far enough to slightly compress the spring.

5. Securely tighten the cap screws (key 14), and refer to the Startup section for adjustment procedures.

## **Parts Ordering**

When corresponding with the Fisher sales office or sales representative about this regulator, include the type number and all other pertinent information stamped on the bottom cap and on the label. Specify the complete 11-character part number from the following parts list when ordering replacement parts.


## NACE Standard MR0175 Compliance


Optional materials are available for applications handling sour gases. These constructions comply with the recommendations of National Association of Corrosive Engineers (NACE) MR0175.

## **Parts List**

Key	Description	Part Number
	Parts Kits (Included are keys 3, 5, 6, 7, 8, 9 and 3 to 150 psig (0,21 to 10,3 bar)	16)
	Type 64, standard construction	R64X0000012
	Type 64, NACE construction	R64X0000N12
	Type 64R	R64RX000012
	Type 64B	R64BX000012
	130 to 200 psig (8,96 to 13,8 bar)	
	Type 64	R64X0000H22
	Type 64R	R64RX000H22
1	Body, aluminum	T1063708012

Key	Description	Part Number
2	Spring Case For use with adjusting screw, aluminum For use with handwheel, aluminum For panel mounting, cast iron	2P901508012 1F8095000A2 2E542919042
3	Valve Plug Spring, steel Types 64 and 64R Type 64B NACE, heat-treated Inconel <sup>(1)</sup>	1D666827222 T1114337022 19A2859X012
4	Control Spring	See Table 1
5	O-Ring Nitrile FKM Nitrile (NH <sub>3</sub> )	1D6825T0012 1D6825X0012 1D682506992
6	Disk Holder Assembly Brass/FKM Types 64 and 64R Type 64B NACE, nitrile rubber/316 stainless steel	1D6656T0012 1D6656000A2 1D6656X0032 1D6656X0032
7	Stem Types 64 and 64B 303 stainless steel NACE, 316 stainless steel Type 64R 303 stainless steel NACE, 316 stainless steel	1D963835172 1D9638X0012 1H911035172 1D9638X0012
8	Stem Guide Types 64 and 64R, brass Type 64B, brass NACE, 316 stainless steel	1D666914092 T11083X0012 1D6669X0012
9	Diaphragm Assembly for specified spring ranges Type 64 3 to 150 psig (0,21 to 10,3 bar), steel, aluminum, nitrile Type 64R 3 to 150 psig (0,21 to 10,3 bar) Steel, brass, nitrile FKM Type 64B 3 to 100 psig (0,21 to 6,90 bar), nitrile	1D6662X0022 1H9112000A2 1H9112T0012 T11059000A2
10	Body Plug, aluminum	1D665209012
11	Upper Spring Seat Steel Type 64R NACE, plated heat-treated	1D667125072
	low-carbon steel	1D6671X0012
12	Adjusting Screw Assembly Adjusting screw CI Spring Case Handwheel assembly Panel mounting assembly	1D995448702 1E543214012 1J4965000A2 1N2005000A2
13	Locknut, steel	1D667728982
14	Cap Screw, plated steel (8 required) For aluminum spring case For cast iron spring case	1A391724052 1P327028982





HANDWHEEL ADJUSTING SCREW

HANDWHEEL ADJUSTING SCREW FOR PANEL MOUNTING



Figure 2. Type 64R Regulator Assembly

## Table 2. Key 25 Bottom-Connected Gauge

CALIBRATION, PSIG (bar)	PART NUMBER
0 to 15 (0 to 1,03) 0 to 30 (0 to 2,07) 0 to 60 (0 to 4,14) 0 to 160 (0 to 11,0)	11B8579X012 11B8579X022 11B8579X032 11B8579X042
0 to 300 (0 to 20,7)	11B8579X052

Key	Description	Part Number	Optional 657 or 667 Series Actuator		
16	Vent or Screen, stainless steel (not shown)	0L078343062	Мо	unting Parts—(not shown)	
19	Adjusting Screw Cap, for cast iron spring case only (not shown)	20B3082X012	Key	Description	Part Number
24	Drive Screw, plated steel (4 required), for cast iron spring case	1E501728982		Mounting Bracket Casing mounting for size 80, plated steel Casing mounting for smaller sizes, steel	1E456825062 1H925525022
25	Gauge	See Table 2			
27	Locknut, aluminum, for cast iron spring case	1N936009012		Yoke mounting for all sizes, steel Cap Screw	1E204225092
42	NACE Tag, 18-8 stainless steel (not shown)	19A6034X012		Casing mounting, plated steel (2 required)	AC856228992
43	Tag Wire, 304 stainless steel (not shown)	1U7581X0022		Yoke mounting, plated steel	1C631224052

#### Industrial Regulators

USA - Headquarters McKinney, Texas 75050 USA Tel: 1-800-558-5856 Outside U.S. 1-469-293-4201

Asia-Pacific Shanghai, China 201206 Tel: 86-21-5899 7887

Europe Bologna, Italy 40013 Tel: 39 051 4190611

#### **Natural Gas Technologies**

USA - Headquarters McKinney, Texas 75050 Tel: 1-800-558-5856 Outside U.S. 1-469-293-4201

Asia-Pacific Singapore, Singapore 128461 Tel: +65 6777 8211

Europe Bologna, Italy 40013 Tel: 39 051 4190611 Gallardon, France 28320 Tel: +33 (0)2 37 33 47 00

#### Industrial/High Purity

TESCOM Elk River, Minnesota 55330 USA Tel: 1-763-241-3238 Selmsdorf, Germany 23923 Tel: +49 (0) 38823 31 0

For further information visit www.emersonprocess.com/regulators

The Emerson logo is a trademark and service mark of Emerson Electric Co. All other marks are the property of their prospective owners. Fisher is a mark owned by Fisher Controls, Inc., a business of Emerson Process Management.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Process Management does not assume responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use and maintenance of any Emerson Process Management product remains solely with the purchaser.

